		Ins	pection, Testing, and Maintenance Stand NFPA 25, Chapter 6 as amended by CC				Page	e 1 of 3	
Date of Inspection, Testing, Maintenance: Property Information: Name: Address: City:					System Riser ID:				
Initial St	ain Test Res atic Pressure: Pressure:	o:	(psi) (psi) (psi)	Abbreviation Key: I = Inspection T = Test M = Maintenance A-O = After Operation MI = Per Manufacturer's Instructions					
Item	Activity	Frequency	Description	•	NFPA 25 Reference	Fail	N/A	Pass	
1.1	I	Quarterly	Control Valves		12.3.2.1				
1.2	I	Quarterly	Pressure Regulating Devices		12.5.2.1 12.5.3.1				
1.3	I	Quarterly	Back Flow Prevention		12.6.1				
1.4	I	Simi Annually	Piping		6.2.1				
1.5	I	Simi Annually	Hose Connections		Chapter 12				
1.6	I	Simi Annually	Cabinet		NFPA 1962				
1.7	I	Simi Annually	Hose		NFPA 1962				
1.8	I	Simi Annually	Hose Storage Device		NFPA 1962				
2.1	Т	Annually	Alarm Device (90 sec)		12.2.7				
2.2	Т	Annually	Hose Nozzle		NFPA 1962				
2.3	Т	Annually	Main Drain Test (Enter Data on Page 1)		12.2.6 12.3.3.4				
2.4	Т	Annually	Control Valve – Position		12.3.3.1				
2.5	Т	Annually	Control Valve – Operation		12.3.3.5				
2.6	Т	Annually	Supervisory		12.3.3.5				
2.7	Т	Annually	Back Flow Prevention Assemblies		12.6.2				

Inspection, Testing, and Maintenance Stand NFPA 25, Chapter 6 as amended by CO	
Date of Inspection, Testing, Maintenance:	System Riser ID: Type of System:
Property Information:	☐ Manual Wet
Name:	☐ Manual Dry ☐ Auto Wet ☐ Auto Dry
Address:	☐ Semi Auto Dry
City:	Class of System: □ Class I □ Class II □ Class III Combination Sprinkler / Standpipe □ Yes □ No

Item	Activity	Frequency	Description	NFPA 25 Reference	Fail	N/A	Pass
2.8	Т	Annually	Pressure Reducing Valve – Partial Flow	12.5.2.3 12.5.3.3			
2.9	Т	5/3-Years	Hose Hydrostatic Test	NFPA 1962			
2.10	Т	5-Years	Hose Storage Device	NFPA 1962			
2.11	Т	5-Years	Pressure Control Valve	12.5.2.2 12.5.3.2			
2.12	Т	5-Years	Pneumatic & Hydrostatic Test	6.3.2			
2.13	Т	5-Years	Flow Test	6.3.1			
2.14	Т	5-Years	Pressure Reducing Valve - Full Flow	12.5.2.2 12.5.3.2			
2.15	Т	5-Years	Fire Department Connection Back Flush	12.7.4			
3.1	M	Annually	Control Valves	12.3.4			
3.2	M	Annually	Hose Connections	Table 6.2.2.2			
3.3	M	Annually	Valves (All Types)	Chapter 12			

		ng, and Maintenance Stand apter 6 as amended by CC		Page 3 of 3
Property Informati Name: Address:	Testing, Maintenance:on:		System Riser ID:	PASADENA FIRE DEPARTMENT
Item	Deficiencies and Comments: Deficiencies and Comments Item	number must correspond to the ite	em number of the activity listed a	above:
	☐ See Continuation Page (s)	_ (Indicate the number of continua	ation pages)	
	□ PASS			
	□ FAIL	SIGNATURE	DATE	