Inspection, Testing, and Maintenance Water Spray Fixed Systems NFPA 25, Chapter 10 as amended by CCR, Title 19 Page 1 of 4 Date of Inspection, Testing, Maintenance: Property Information: Name: Address: Address: Address: Address: City:

Item	Activity	Frequency	Description	NFPA 25 Reference	Fail	N/A	Pass
1.1	I	Each Shift	UHSWSS Controllers	10.4.3			
1.2	I	Each Shift	UHSWSS – Valves	10.4.4			
1.3	I	Daily/Weekly	Heat (deluge valve house)	10.2.1.5, Chapter 12			
1.4	I	Daily/Weekly Monthly Quarterly Annually 3-5 Years	Tanks (Gravity, Pressure, and Suction)	10.2.10 Chapter 9			
1.5	I	Monthly	Nozzles	10.2.1.1 10.2.1.2 10.2.1.6 10.2.5.1 10.2.5.2			
1.6	I	Quarterly	UHSWSS – detectors	10.4.2			
1.7	I	Quarterly	Backflow prevention	12.6.1			
1.8	I	Quarterly	Control Valves	12.3.2.1			
1.9	I	Quarterly	Drainage	10.2.8			
1.10	I	Quarterly	Fittings	10.2.4 10.2.4.1			
1.11	I	Quarterly	Fittings (rubber gasketed)	10.2.4.1 A. 10.2.4.1			
1.12	I	Quarterly	Hangers	10.2.4.2			
1.13	I	Quarterly	Pipe	10.2.1.1 10.2.1.2 10.2.4 10.2.4.1			
1.14	I	Quarterly	Supports	10.2.1.1 10.2.1.2 10.2.4.2			
1.15	I	Quarterly Annually 5 Years	Deluge valve	10.2.2 12.4.3.1			

Inspection, Testing, and Maintenance Water Spray Fixed Systems NFPA 25, Chapter 10 as amended by CCR, Title 19

Page 2	2 of 4
--------	--------

Date of Inspection, Testing, Maintenance:	System Riser ID:				
Property Information:	OF PASADELL				
Name:	Abbreviation Key:				
Address:	I = Inspection T = Test				
City:	M = Maintenance A-O = After Operation MI = Per Manufacture				

Item	Activity	Frequency	Description	NFPA 25 Reference	Fail	N/A	Pass
1.16	I	5 - Years	Check Valves (including Detector Check)	12.4.2.1			
1.17	I	MI	Strainers	10.2.7			
1.18	I	NFPA 72	Detection System	10.2.3 NFPA 72			
1.19	I	See Fire Pump Form	Electric Motor	10.2.9 Chapter 8			
1.20	Ι	See Fire Pump Form	Engine Drive	10.2.9 Chapter 8			
1.21	I	See Fire Pump Form	Fire Pump	10.2.9 Chapter 8			
1.22	I	See Fire Pump Form	Steam Driver	10.2.9 Chapter 8			
1.23	Ι	See Private Fire Main Form	Water Supply Piping	10.2.6.1 10.2.6.2 Chapter 7			
2.1	T	Annually	Backflow Prevention	12.6.2			
2.2	T	Annually	Control Valves	12.3.3			
2.3	Т	Annually	Main Drain Test	12.2.6 12.3.3.4			
2.4	Т	Annually	Flushing	10.2.1.3 Section 10.3 (flushing of connection to riser, part of annual test).			
2.5	Т	Annually	Manual Release	10.2.1.3 10.3.6			
2.6	Т	Annually	Nozzles	10.2.1.3 10.2.1.6 Section 10.3			
2.7	Т	Annually/ 3 - Years	Water Spray System Test	Section 10.3 12.4.3.2			
2.8	Т	Annually	Strainers	10.2.1.3 10.2.1.7 10.2.7			
2.9	T	Annually	Water-flow alarm	Chapter 5			
2.10	Т	Annually	UHSWSS	Section 10.4			

Inspection, Testing, and Maintenance Water Spray Fixed Systems NFPA 25, Chapter 10 as amended by CCR, Title 19

Page	3	of	4
------	---	----	---

Date of Inspection, Testing, Maintenance:	System Riser ID:					
Property Information:	OF PASADEA					
Name:	Abbreviation Key:					
Address:	I = Inspection T = Test M = Maintenance					
City:	A-O = After Operation MI = Per Manufacture					

Item	Activity	Frequency	Description	NFPA 25 Reference	Fail	N/A	Pass
2.11	T	Annually 3 - Years	Deluge Valve	10.2.2, Chapter 12			
2.12	T	NFPA 72	Detection Systems	10.2.3 NFPA 72			
2.13	T	See Fire Pump Form	Electric Motor	10.2.9, Chapter 8			
2.14	T	See Fire Pump Form	Engine Drive	10.2.9 Chapter 8			
2.15	T	See Fire Pump Form	Fire Pump	10.2.9 Chapter 8			
2.16	Т	See Water Storage Tank Form	Tanks (Gravity, Pressure, Suction)	10.2.10 Chapter 9			
2.17	T	See Fire Pump Form	Steam Driver	10.2.9 Chapter 8			
2.18	Т	See Private Fire Main Form	Water Supply Flow Test	7.3.2			
3.1	M	Annually	Control Valves	10.2.1.4 12.3.4			
3.2	М	Annually	Strainers	10.2.1.4 10.2.1.7 10.2.7			
3.3	M	Annually	Water Spray System	10.2.1.4 Chapter 12			
3.4	М	Annually 5 – Years / AO	Deluge Valve	10.2.2 12.4.3.3			
3.5	М	5 - Years	Strainers (baskets/screen)	10.2.1.4 10.2.1.8 A. 10.2.7			
3.6	M	NFPA 72	Detection Systems	10.2.3 NFPA 72			
3.7	M	Per AHJ / MI	Backflow Prevention	12.6.3			
3.8	M	MI	Check Valves (including detector check valves)	12.4.2.2			
3.9	M	See Fire Pump Form	Electric Motor	10.2.9, Chapter 8			
3.10	M	See Fire Pump Form	Engine Drive	10.2.9, Chapter 8			
3.11	M	See Fire Pump Form	Fire Pump	10.2.9, Chapter 8			

			n, Testing, and Maintenance Wa NFPA 25, Chapter 10 as amend			S	Pag	ge 4 of 4
Date of I	nspection T		nce:		stem Riser ID: _			,0 1 01 1
	_	_			mem ruser 12		OF PASAD	d
Property Information: Name:					breviation Key:	**	3	27
Address:				I =	Inspection	*INCORPO	RATED	FIRE CHIEF
ridaress.				M :	Test Maintenance		PA	MDENA FIRE
City:	-				O = After Opera = Per Manufact		-	CID
		T			L MED 4.05	ı	<u> </u>	1
Item	Activity	Frequency	Description		NFPA 25 Reference	Fail	N/A	Pass
3.12	M	See Water Storage Tank Form	Tanks (Gravity, Pressure, Suction)		10.2.10, Chapter 9			
3.13	M	See Fire Pump Tank Form	Steam Driver		10.2.9, Chapter 8			
Item	Deficiencio	es and Comments	s Item number must correspond to the ite	em number of t	he activity listed	l above:		
		Page (s) (In	ndicate the number of continuation page	es)				
□ PASS								
□ FAIL			SIGNATURE	I	DATE	_		