

- BODY, COVER, AND EXTENSIONS SHALL BE REINFORCED WITH A MINIMUM OF TWO NO. 9 GAGE WELDED WIRE LOOPS, OR EQUIVALENT.
- 2. COVER SHALL BE OF THE BOLT DOWN TYPE AND SHALL HAVE LIFT EYES OF 9.5 mm (3/8") GALVANIZED STEEL CAST IN PLACE.
- GROUT OPENING AFTER CONDUIT IS IN PLACE.
- 4. EXTENSIONS (229 mm [9"] MIN. DEPTH) SHALL BE INSTALLED WHERE REQUIRED ON THE PLANS.
- 5. PULL BOXES SHALL NOT BE PLACED IN DRIVEWAY AREAS, EXCEPT AS PERMITTED BY ENGINEER.
- 6. BOX OR EXTENSIONS SHALL HAVE ONE BREAKOUT PANEL EACH SIDE.
- COVER LETTERING SHALL BE 25 mm (1") INCISED LETTERS APPROPRIATELY READING "TRAFFIC SIGNAL", "STREET LIGHTING" (FOR MULTIPLE SYSTEMS), OR STREET LIGHTING - HIGH VOLTAGE" (SERIES SYSTEM).
- 8. CONTRACTOR SHALL SUBMIT DOCUMENTATION FROM THE MANUFACTURER CERTIFYING COMPLIANCE WITH ALL DETAILS ON THIS STANDARD PLAN.

* - EXACT CONVERSION (ENGLISH DIMENSION WILL REMAIN).

CITY OF PASADENA - PUBLIC WORKS & TRANSPORTATION DEPARTMENT DRAWN BY: REVISION: UNITS: **PULL BOX BANG CHAU** DUAL 2 STREET LIGHT AND STANDARD PLAN: CHECKED BY: TRAFFIC SIGNAL **CATHY CHANG** SUBMITTED BY: JIM VALENTINE SHEET 1 OF 3 8660 EXPIRES JUNE 30, 2004 \$973-1-REV2.DVG 4/24/0