

# Appendix I

## Correspondence, City of Pasadena Fire Department





**OFFICE OF THE FIRE MARSHAL**

June 27, 2013

TO: Kevin Johnson, Planner

SUBJECT: 86 South. Fair Oaks Ave. Project

The City of Pasadena Fire Department is responsible for providing fire protection and emergency response to the project site and throughout the City of Pasadena by using a road that provides fire apparatus access from fire station to a facility, building or portion thereof. This is a general term inclusive of all other terms such as fire lane, public street, private street, parking lot lane and access roadway. Fire apparatus access roads shall have an unobstructed width of not less than 20 feet exclusive of shoulders as defined in the California Fire Code (CFC) Section 503.2.1

Dayton Street is an established public street and complies with the requirements of CFC.

If you have any questions, please contact Fire Chief, Calvin E. Wells, at 744-4675.

CC: Anthony Bagan, Deputy Fire Marshal  
Pari Bagayee, Supervising Fire Plan Examiner

U; PB 06/13/2013EIR